

Product certificate number

No: 2613/0352/IEC62116/E6-CER

Manufacturer

Fronius International GmbH
Fronius Straße 5, A-4642 Sattledt, Austria

Trademark / Logotipo



Model

**Fronius Galvo 1.5-1 / Fronius Galvo 2.0-1 / Fronius Galvo 2.5-1 /
Fronius Galvo 3.0-1 / Fronius Galvo 3.1-1**

Type of generating unit

Static Power Converter

Technical Data

| | | | | | |
|--------------------------|------------------|-------------|---------------|-------------|---------------|
| Nominal Power | 1,5 kW | 2 kW | 2,5 kW | 3 kW | 3,1 kW |
| Rated Voltage | 220-230 V | | | | |
| Nominal Frequency | 50 Hz | | | | |

Firmware version

**RECERBO: V0.3.23.0
GALVO_PS: V0.1.5.0
GALVO_FIL: V0.1.1.4**

Number of phases
Isolation Transformer

Single phase
YES

Standard

IEC 62116:2014. Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters.

The above-mentioned generating unit is certified according the SGS internal procedure PE.T-ECPE-18 based on the requirements of the UNE-EN ISO / IEC 17065.

This certificate cancels and supersedes certificate number 2613/0352/IEC62116/E5-CER.

This certificate is valid until: 4th of May of 2022. First issued on 7th of August of 2013.

Madrid, 3rd of February 2020

Daniel Arranz Muñiz
Certification Manager

