ENAC
CERTIFICACIÓN
N° 87/C-PR244

SGS

Product certificate number **No: 2613/0865/1/E4-CER**

Manufacturer	**Fronius International GmbH** Fronius Straße 5, A-4642 Sattledt, Austria					
Trademark	Fronius					
Model	**FRONIUS SYMO 10.0-3-M / FRONIUS SYMO 12.5-3-M / FRONIUS SYMO 15.0-3-M / FRONIUS SYMO 17.5-3-M / Fronius SYMO 20.0-3-M**					
Type of generating unit	**Static Power Converter**					
Technical Data	**Nominal Power**	**10 kW**	**12,5 kW**	**15 kW**	**17,5 kW**	**20 kW**
	Rated Voltage	**220-230 V**				
	Nominal Frequency	**50 Hz**				
	Firmware version	**RECERBO: V0.3.23.0** **Power Stage: V1.2.11.1** **Filter: V0.9.24.1**				
	Number of phases	**Three phase**				
	Isolation Transformer	**No**				
Standard	**IEC 62116:2014.** Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters.					

The above-mentioned generating unit is certified according the SGS internal procedure PE.T-ECPE-18 based on the requirements of the UNE-EN ISO / IEC 17065.

This certificate cancels and supersedes certificate number 2613/0865/1/E3-CER.

This certificate is valid until: 06th of February of 2023. First issued on 06th of February of 2014.

Madrid, 03rd of February 2020

Daniel Arranz Muñiz
Certification Manager